

## HYDE ES LEAD WATER TEST RESULTS



## **Initial Filter Test After Installation**

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	HYDE ELEMENTARY SCHOOL	WS- 010128	12/14/2016	3	Break Room	In break room		FT-112016-010128-A	< 1	FT-112016-010128-B	< 1
2	HYDE ELEMENTARY SCHOOL	WS- 010148	12/14/2016	Ground Floor	Combo Faucet	In classroom 102 Le	eft	FT-112016-010148-A	< 1	FT-112016-010148-B	< 1
3	HYDE ELEMENTARY SCHOOL	WS- 010126	12/14/2016	3	Combo Faucet	In classroom 302 Le	eft	FT-112016-010126-A	< 1	FT-112016-010126-B	< 1
4	HYDE ELEMENTARY SCHOOL	WS- 010142	12/14/2016	Ground Floor	Combo Faucet	In library room 101 Le	eft	FT-112016-010142-A	< 1	FT-112016-010142-B	< 1
5	HYDE ELEMENTARY SCHOOL	WS- 010133	12/14/2016	3	Combo Faucet	In classroom 301 Le	eft	FT-112016-010133-A	< 1	FT-112016-010133-B	< 1
6	HYDE ELEMENTARY SCHOOL	WS- 010131	12/14/2016	3	Combo Faucet	In classroom 304 Le	eft	FT-112016-010131-A	1.2	FT-112016-010131-B	< 1
7	HYDE ELEMENTARY SCHOOL	WS- 010139	12/14/2016	2	Combo Faucet	In classroom 205 Le	eft	FT-112016-010139-A	1	FT-112016-010139-B	< 1
8	HYDE ELEMENTARY SCHOOL	WS- 010129	12/14/2016	3	Combo Faucet	In classroom 305 Le	eft	FT-112016-010129-A	< 1	FT-112016-010129-B	< 1
9	HYDE ELEMENTARY SCHOOL	WS- 010135	12/14/2016	2	Combo Faucet	In classroom 201 Le	eft	FT-112016-010135-A	< 1	FT-112016-010135-B	< 1
10	HYDE ELEMENTARY SCHOOL	WS- 010137	12/14/2016	2	Combo Faucet	In classroom 202 Le	eft	FT-112016-010137-A	< 1	FT-112016-010137-B	< 1

## First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

6 HYDE ELEMENTARY SCHOOL	WS- 010131	1/25/2017	3	Combo Faucet In classroom 304	Left	FT-112016-010131-A	< 1	FT-112016-010131-B	< 1